



NOTE:

COPPERHORN (METER SETTER) AND METER WILL BE INSTALLED BY THE WATER COMPANY; ALL OTHER PIPING BY CUSTOMER.

COPPERHORN NO.	METER SIZE	"A" MIN.	"B"		"C" MIN.	"D" I.P. OR COPPER	"E" MIN.
			MIN.	MAX.			
1	5/8"	6'-0"	18"	36"	18"	3/4"	2"
2	5/8" X 3/4"	6'-0"	18"	36"	18"	3/4"	2"
3	3/4"	6'-0"	18"	36"	18"	3/4"	2"
4	1"	6'-0"	18"	36"	18"	1"	2"

NOTES:

1. METER MUST BE LOCATED WHERE SERVICE LINE ENTERS PREMISES.
2. NO STORED MATERIALS OR OTHER OBSTRUCTIONS TO BE PLACED IN PATH OF ACCESS TO METER.

TYPICAL INSIDE SET DIAGRAM (For Edison Water and Liberty Water)

NEW JERSEY AMERICAN WATER COMPANY - FIELD SERVICE DEPARTMENT