


PLAN

FINISHED GRADE



PIPE SIZE

- 2" - USE 1 SACK (MIN.)
- 4" - USE 2 SACKS (MIN.)
- 6" - USE 2 SACKS AND BLOCKING PAD (MIN.)

ELEVATION

(FOR 2", 4", AND 6" DIA. PIPE ONLY)

NOTE:

FOR BLOCKING OF PIPE SIZES 8" AND LARGER, SEE DWG. NO. 0201-0601-SD6

REVISIONS

MISSOURI AMERICAN WATER STANDARD
CIVIL
THRUST BLOCK AT HORIZONTAL BENDS
6" OR LESS DETAIL

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141



AMERICAN WATER

DRAWN BY KKM
PROJECT ENG'R
APPROVED

DATE 11-13-08
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

0201-0601-SD17