

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

WVAW- GASSAWAY, WV3300406

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 1/1/2024 and 12/31/2024, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
03, MONITORING, ROUTINE MAJOR 1 st Q 2024 BHC - Gamma Sample Results Not Submitted	1/1/2024 to 12/31/2024

What happened? What is being done? (Describe corrective action)

Samples for BHC-Gamma, also known as Lindane, were collected in April 2024 instead of during their required sampling window of January to March 2024, per regulatory requirements. All testing completed in April showed values for BHC- Gamma are below the detection limit of the analyzing instrument, and thus considered non-detectable. No further action is required at this time.

For more information, please contact Jon Jarvis at 1800-685-8660
(Contact name) (Phone number)

Or 100 Dryden Street, Charleston, WV 25301
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **WVAW- GASSAWAY**

State Water System ID#: WV3300406

Date Distributed: _____